



- NOTES:**
- DO NOT CONNECT LINE CONFIGURATIONS OTHER THAN AS SPECIFIED.
 - USE CONDUCTORS RATED FOR 600V MINIMUM.
 - FOR USE ON A SOLIDLY GROUNDED WYE SOURCE ONLY.
 - CLASS 1 CONTROL CIRCUIT: < 5V, < 1VA.
 - "CT" IS AN ABBREVIATION FOR "CURRENT TRANSFORMER".
 - FIELD WIRING TERMINALS ARE MARKED WITH A CIRCLE (○).

CURRENT TRANSFORMER CONNECTIONS
 ABOVE ILLUSTRATES A TYPICAL SETUP. FROM ONE TO THREE CURRENT TRANSFORMERS MAY BE CONNECTED TO WATTNODE METER M1. CURRENT TRANSFORMERS ARE NOT PROVIDED WITH THE PANEL AND SHALL BE PROVIDED BY THE INSTALLER.

Meter Enclosure			
DRAWING # ME1-C-1_Wiring_3Y480_RevA			
PART # ME1-C-1		NAME	DATE
REVISION: A	DRAWN	CAH	07/12/2018
SHEET: 1 OF 1	CHECKED	NWC	07/12/2018

**Continental
Control
Systems, LLC**

Socomec Group

www.ctlsys.com (303) 444-7422