



**NOTES:**

- DO NOT CONNECT LINE CONFIGURATIONS OTHER THAN AS SPECIFIED.
- USE CONDUCTORS RATED FOR 600V MINIMUM.
- FOR USE ON A SOLIDLY GROUNDED WYE SOURCE ONLY.
- CLASS 1 CONTROL CIRCUIT: < 5V, < 1VA.
- "CT" IS AN ABBREVIATION FOR "CURRENT TRANSFORMER".
- FU1, FU2, AND FU3 MUST BE REPLACED WITH CLASS CC 1/2A, 600VAC TIME-DELAY FUSES.
- DO NOT OPERATE THIS FUSEHOLDER UNDER LOAD. THIS FUSEHOLDER IS NOT A MEANS OF DISCONNECT. A MEANS OF DISCONNECT SHALL BE PROVIDED BY THE INSTALLER.
- FIELD WIRING TERMINALS ARE MARKED WITH A CIRCLE (○).

**CURRENT TRANSFORMER CONNECTIONS**

ABOVE ILLUSTRATES A TYPICAL SETUP. FROM ONE TO THREE CURRENT TRANSFORMERS MAY BE CONNECTED TO WATTNODE METER M1. CURRENT TRANSFORMERS ARE NOT PROVIDED WITH THE PANEL AND SHALL BE PROVIDED BY THE INSTALLER.

<b>Meter Enclosure</b>			
DRAWING # ME1-F-1_Wiring_3Y600_RevA			
PART #	ME1-F-1	NAME	DATE
REVISION: A		DRAWN CAH	07/12/2018
SHEET: 1 OF 1		CHECKED NWC	07/12/2018

**Continental Control Systems, LLC**

Socomec Group

www.ctlsys.com (303) 444-7422